



PRODUCT PERFORMANCE RATING

Document ID 100320191400-9655703

Issued on 3 October 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 19.02.064

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Temporal variation of thermostatic heads / Variation temporelle (TV)
Product type	TV
Brand	RBM
Range	2634
Product référence	2634

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
RBM	RBM	RBM	France

FEATURE	VALUE	UNIT
Factory city	NAVE (BS)	
Factory country	Italy	

FEATURE	VALUE	UNIT
TRV		
D0VT	0.40	K



PRODUCT PERFORMANCE RATING

Document ID 100320191400-9655703

Issued on 3 October 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 19.02.064

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEAD		
CH	0.30	K
DH	0.20	K
WH	0.50	K
ZH	25.00	min

FEATURE	VALUE	UNIT
GENERAL		
Type thermostatic valve	With integral sensor	